

Re: Pineview Highest Allowable Results



Aaron Setran to: Brenda Stein

09/03/2009 08:39 AM

	Aaron Setran	see page 8 of the permit, Section D.2.a.ii. If effluent concentrations for
1		

see page 8 of the permit, Section D.2.a.ii. If effluent concentrations for TSS, BOD and N-N exceed the stated limits, re-sampling and notification to EPA are required. Detection of Fecal Coliform or Nitrates in the monitoring wells (see Section D.2.a.iii) has the same requirements. I know that this permit is not the easiest permit to follow, and that will change once we re-issue it......but first we have to find out who currently owns the wastewater infrastructure; any ideas?

Aaron Carr Setran U.S. EPA, Water Division 75 Hawthorne St. San Francisco, CA 94105 (415) 972-3457

"Brenda Stein" brenda@exdengineering.com>

"Brenda Stein"

brenda@exdengineering.com

09/02/2009 04:38 PM

To

Aaron Setran/R9/USEPA/US@EPA

CC

Subject

Pineview Highest Allowable Results

Aaron,

Where can I find the highest allowable results for the sampling for Pineview? I need to know when the results are too high for EPA standards.

I need to know for the following:

Total suspended solids in mg/L Nitrate Nitrogen in mg/L Biochemical Oxygen Demand in mg/L Total KJeldahl Nitrogen in mg/L

It was never part of the permit and I need to be sure I respond correctly if the results detected in sampling are too high.

Can you help?

Brenda Stein P.E., M.B.A.

Principal Engineer brenda@exdengineering.com



Ph: (775) 783-4772 Fx: (775) 783-4773

